






Digos Water District

Water Statistics (May 2020)



Digos Water District


Water Statistics (May 2020)



Water Quality

Microbiological Test

Population actually served by utility	115,370
Required minimum number of samples	24
No. of samples examined	24
<ul style="list-style-type: none"> ○ Total Coliform ○ Thermotolerant Coliform / E. coli ○ Heterotrophic Place Count (HPC) 	Met Standards
Disinfection Residual <i>Using Free Residual Chlorine</i> Standards Range = 0.3 ppm - 1.5 ppm	
<ul style="list-style-type: none"> ○ No. of days without a test conducted ○ Average Chlorine Residual 	0 out of 31 days 0.47 ppm



EMPLOYEE PROFILE

