






Digos Water District

Water Statistics (September 2021)



Digos Water District

Water Statistics (September 2021)



Microbiological Test

Population actually served by utility	122,925
Required minimum number of samples	25
No. of samples examined	25
● Total Coliform	Met Standards
● Thermotolerant Coliform / E. coli	Met Standards
● Heterotrophic Place Count (HPC)	Met Standards
Disinfection Residual (Standards Range = 0.3ppm - 1.5ppm)	
● No. of days without a test conducted	0 out of 30 days
● Average Chlorine Residual	0.48 ppm

