






# Digos Water District

## Water Statistics (March 2024)



# Digos Water District

## Water Statistics (March 2024)



### Microbiological Test

Population actually served by utility	136,405
Required minimum number of samples	26
No. of samples examined	26
● Total Coliform	<b>Met Standards</b>
● Thermotolerant Coliform / E. coli	<b>Met Standards</b>
● Heterotrophic Place Count (HPC)	<b>Met Standards</b>
Disinfection Residual (Standards Range = 0.3ppm - 1.5ppm)	
● No. of days without a test conducted	<b>0 out of 31 days</b>
● Average Chlorine Residual	<b>0.49 ppm</b>

